



CHERIE K. BERRY
COMMISSIONER

JONATHAN R. BROOKS
BUREAU CHIEF
ELEVATOR AND AMUSEMENT DEVICE BUREAU

February 21, 2006

MEMO TO: All Elevator Companies

RE: Adoption of the ASME A17.1 Supplement

Effective 2/12/06 the N. C. Department of Labor has adopted the A17.1 2005 Supplement in its entirety. Companies will no longer be required to submit a variance request to install machine roomless elevator systems. Companies will, however, be required to submit a request for variance for the alternative suspension means as the A17.1 Committee has not yet published its approval, inspection guidelines, and testing procedures.

If you have any further questions regarding this matter, please contact our office.

Respectfully,

Thomas M. Chambers
Assistant Bureau Chief

/nfv