



CHERIE K. BERRY
COMMISSIONER

JONATHAN R. BROOKS
BUREAU CHIEF
ELEVATOR AND AMUSEMENT DEVICE BUREAU

March 8, 2006

MEMO TO: ALL ELEVATOR COMPANIES

FROM: Thomas M. Chambers
Assistant Bureau Chief

RE: Revision to Directive – Utilization Equipment

After review of Article 620.55 Utilization Equipment, it was determined that only equipment directly controlled by or physically connected to the elevator control will require a disconnecting means as outlined in Article 620.55.

When conducting inspections, our inspectors will refer to the electrical inspector if any clarification is needed for that specific installation. This is effective March 7, 2006.

If you should have any questions, please contact our office.

/nfv